Energy performance certificate (EPC)		
10, Whinstone Mews Station Road NEWCASTLE UPON TYNE NE12 8AZ	Energy rating	Valid until: 30 January 2022 Certificate number: 0996-2859-6996-9272-4265
Property type		Ground-floor flat
Total floor area		81 square metres

### Rules on letting this property


Properties can be rented if they have an energy rating from A to E.

If the property is rated F or G, it cannot be let, unless an exemption has been registered. You can read guidance for landlords on the regulations and exemptions (https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

# Energy efficiency rating for this property

This property's current energy rating is C. It has the potential to be C.

<u>See how to improve this property's energy</u> performance.



The graph shows this property's current and potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher the number the lower your fuel bills are likely to be.

For properties in England and Wales:

the average energy rating is D the average energy score is 60

## Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says "assumed", it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

Feature	Description	Rating
Wall	Cavity wall, as built, insulated (assumed)	Good
Window	Fully double glazed	Average
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Programmer, room thermostat and TRVs	Good
Hot water	From main system	Good
Lighting	No low energy lighting	Very poor
Roof	(another dwelling above)	N/A
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	None	N/A

#### Primary energy use

The primary energy use for this property per year is 175 kilowatt hours per square metre (kWh/m2).

Environmental imp property	act of this	This property produces	2.7 tonnes of CO2
This property's current env rating is C. It has the poter	•	This property's potential production	2.3 tonnes of CO2
Droportion are roted in a a	ala fram A ta C		
Properties are rated in a se based on how much carbo produce.	n dioxide (CO2) they	By making the <u>recommend</u> could reduce this property's 0.4 tonnes per year. This w environment.	s CO2 emissions by
based on how much carbo	n dioxide (CO2) they	could reduce this property's 0.4 tonnes per year. This w	s CO2 emissions by

### How to improve this property's energy performance

Making any of the recommended changes will improve this property's energy efficiency.

If you make all of the recommended changes, this will improve the property's energy rating and score from C (71) to C (75).

Recommendation	Typical installation cost	Typical yearly saving
1. Low energy lighting	£20	£41
2. Condensing boiler	£1,500 - £3,500	£49

#### Paying for energy improvements

Find energy grants and ways to save energy in your home. (https://www.gov.uk/improve-energy-efficiency)

## Estimated energy use and potential savings

Estimated yearly energy cost for this property	£608
Potential saving	£89

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

The estimated saving is based on making all of the recommendations in <u>how to improve this</u> <u>property's energy performance</u>.

For advice on how to reduce your energy bills visit <u>Simple Energy Advice</u> (<u>https://www.simpleenergyadvice.org.uk/</u>).

#### Heating use in this property

Heating a property usually makes up the majority of energy costs.

#### Estimated energy used to heat this property

Space heating	6255 kWh per year
Water heating	2638 kWh per year

## Potential energy savings by installing insulation

The assessor did not find any opportunities to save energy by installing insulation in this property.

You might be able to receive <u>Renewable Heat</u> <u>Incentive payments (https://www.gov.uk/domestic-renewable-heat-incentive)</u>. This will help to reduce carbon emissions by replacing your existing heating system with one that generates renewable heat. The estimated energy required for space and water heating will form the basis of the payments.

## Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

#### Assessor contact details

Assessor's name	Alan Matthewson
Telephone	0191 2843185
Email	armenergyreports@aol.com
Accreditation scheme contact details	

Accreditation scheme Assessor ID Telephone Email

#### Assessment details

Assessor's declaration Date of assessment Date of certificate

Type of assessment

ECMK ECMK200843 0333 123 1418 info@ecmk.co.uk

No related party 31 January 2012 31 January 2012 RdSAP