Energy performance certificate (EPC)		
6 Cole Close Nether Stowey BRIDGWATER TA5 1JU	Energy rating	Valid until: <b>15 May 2032</b> Certificate number: <b>0330-2527-3150-2392-0685</b>
Property type		Detached house
Total floor area	108 square metres	

# Rules on letting this property

Properties can be let if they have an energy rating from A to E.

You can read <u>guidance for landlords on the regulations and exemptions</u> (<u>https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance</u>).

### **Energy rating and score**

This property's current energy rating is C. It has the potential to be B.

<u>See how to improve this property's energy</u> <u>efficiency</u>.

	Energy rating	Current	Potential
92+	Α		
81-91	В		88 B
69-80	С	78 C	
55-68	D		
39-54	E		
21-38	F		
1-20	C	•	

The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

the average energy rating is D the average energy score is 60

# Breakdown of property's energy performance

### Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Cavity wall, as built, insulated (assumed)	Good
Roof	Pitched, 200 mm loft insulation	Good
Window	Fully double glazed	Good
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Programmer, room thermostat and TRVs	Good
Hot water	From main system	Good
Lighting	Low energy lighting in all fixed outlets	Very good
Floor	Solid, insulated (assumed)	N/A
Secondary heating	None	N/A

#### Primary energy use

The primary energy use for this property per year is 129 kilowatt hours per square metre (kWh/m2).

## How this affects your energy bills

An average household would need to spend **£574 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £27 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2022** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

#### Heating this property

Estimated energy needed in this property is:

- 6,865 kWh per year for heating
- 2,045 kWh per year for hot water

## Impact on the environment

This property's current environmental impact	
rating is C. It has the potential to be B.	

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year.

#### **Carbon emissions**

An average household 6 tonnes of CO2 produces

This property produces2.5 tonnes of CO2This property's<br/>potential production1.3 tonnes of CO2

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

### Changes you could make

Step	Typical installation cost	Typical yearly saving
1. Solar water heating	£4,000 - £6,000	£27
2. Solar photovoltaic panels	£3,500 - £5,500	£376

#### Help paying for energy improvements

You might be able to get a grant from the <u>Boiler Upgrade Scheme (https://www.gov.uk/apply-boiler-upgrade-scheme</u>). This will help you buy a more efficient, low carbon heating system for this property.

#### More ways to save energy

Find ways to save energy in your home by visiting www.gov.uk/improve-energy-efficiency.

# Who to contact about this certificate

#### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Alister Paisley
Telephone	0203 397 8220
Email	support@epconline.co.uk

#### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/024383
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

#### About this assessment

Assessor's declaration	No related party
Date of assessment	13 May 2022
Date of certificate	16 May 2022
Type of assessment	RdSAP